



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

BEVERLY EAVES PERDUE
GOVERNOR

EUGENE A. CONTI, JR.
SECRETARY

ADDENDUM 2

DMV IREDELL COUNTY REGIONAL CDL TESTING FACILITY
STATESVILLE, NC SCO ID# 11-09038-01A
JANUARY 17, 2012

PLEASE NOTE RECEIPT OF THIS ADDENDUM (# 2) ON YOUR BID

***SEALED BIDS WILL BE RECEIVED UNTIL 10:30 AM, THURSDAY, JANUARY 19, 2012,
DIVISION 12, DISTRICT 2 RESIDENT ENGINEERS CONFERENCE ROOM,
124 Prison Camp Road, Statesville, NC 28625 (Division Office phone number: 704-876-3947)***

ITEM 1: Clarifications and answers provided by the Design team:

Lime:

- a. The quantity of lime required is in the range of 3.5 to 6.5 percent by weight.
- b. Compact specimens to a minimum density of 95% of maximum dry density obtained by AASHTO T99.
- c. Do not immerse the specimens in water at the end of the curing period.
- d. Select the rate of lime that provides a minimum unconfined compressive strength of 58 PSI (400 KPA).

End of Addendum 2

MAILING ADDRESS:
NC DEPARTMENT OF TRANSPORTATION
GENERAL SERVICES DIVISION
1525 MAIL SERVICE CENTER
RALEIGH NC 27699-1525

TELEPHONE: 919-715-0400
FAX: 919-715-0399

WEBSITE: WWW.NCDOT.ORG

LOCATION:
TRANSPORTATION BUILDING
1 SOUTH WILMINGTON STREET
RALEIGH NC